

## Digital Simulation of Closed Loop Controlled IPFC Using PSPICE

<sup>1</sup>S. Sankar and <sup>2</sup>S. Ramareddy

<sup>1</sup>Sathyabama University, Chennai-600 119, India

<sup>2</sup>Department of IEEE., Jerusalem College of Engineering, Chennai-601 302, India

**Abstract:** This study describes closed loop controlled inter Line Power flow controller used in power system. An Inter line power flow controller is VSC-based FACTS controller for series compensation with the unique capability of power management among multilines of a sub-station. The FACTS technology is essential to alleviate these difficulties by enabling utilities to get most service from their transmission facilities. FACTS controllers can control series impedance, shunt impedance, current, voltage and phase angle. Different FACTS controller's circuits are simulated using PSPICE software package. IPFC is used to improve the power flow and to provide a power balance of a transmission system. The circuit model of IPFC was developed and the same is used for simulation.

**Key words:** FACTS, SSSC, IPFC, TCR, PSPICE

### INTRODUCTION

As a result of Flexible AC transmission system, considerable effort has been spent in recent years on the development of power electronics based power flow controllers (Hingorani and Gyugyi, 2000). They employ self-commutated inverters as synchronous voltage sources. The power electronics based voltage sources can internally generate and absorb reactive power without the use of capacitors and reactors. They can facilitate both real and reactive power compensation and thereby can provide independent control for real and reactive power flow (Song and Johns, 1999; Gyugyi, 2000).

The Interline Power Flow Controller (IPFC) scheme proposed provides, together with independent controllable reactive series compensation of each individual line, a capacity to directly transfer real power between the compensated lines. This capability makes it possible to equalize both real and reactive power flow between the lines; transfer power demand from overland to under loaded lines; compensate against resistive line voltage drops and the corresponding reactive power demand; increase the effectiveness of the overall compensating system for dynamic disturbances (Gyugyi, 1998, 1999). The IPFC can potentially provide an effective scheme for power transmission management at a multi-line substation. In the literature (Hingorani and Gyugyi, 2000) to, the simulation of closed loop system with phase angle difference is not presented. In the present work, the circuit model for closed controlled IPFC is developed and the same is used for simulation.

### INTERLINE POWER FLOW CONTROLLER

The basic principles of the Interline Power Flow Controller (IPFC) employs a number of DC to AC inverters each providing series compensation for different line as showing in Fig. 1. The series compensation is provided by Static Synchronous Series Compensators (Papic, 1997). The compensating inverters are linked together at the DC terminals. The compensators in addition to provide series reactive compensation can be controlled to supply real power exchange through the dc link from its own transmission line (Sen, 1998). Thus surplus power available in underutilized lines is made available by other lines. This arrangement mandates the rigorous maintenance the overall power balance at the dc




Fig. 1: Block diagram of an inter line power flow controller




Fig. 2: Basic interline power flow controller




Fig. 3: For prime system and phasor diagram




Fig. 4: Variation of the real and reactive power with respect to phase angle

common of terminal by appropriate control action, using the general principle that the under loaded lines are to provide help, in the form of appropriate real power transfer, for the overloaded lines (Zhang, 2003; Jianhong *et al.*, 2002). The elementary IPFC scheme consisting of 2 back-to-back dc to ac inverters each compensating a transmission line by series voltage injection is shown in Fig. 2, Two synchronous voltage sources with phasors  $V_{1pq}$  and  $V_{2pq}$  in series with transmission lines 1 and 2, represent the two back-to-back dc to ac inverters. The common dc link is represented by a bi-directional link for real power exchange between the two voltage sources. Transmission Line 1, represented by reactance  $X_1$ , has sending end bus with voltage phasor  $V_{1r}$ . The sending end voltage phasor of line 2, represented by reactance  $X_2$ , is  $V_{2s}$  and the receiving end voltage phasor is  $V_{2r}$ .

All sending end and receiving end voltages are constant with fixed amplitudes,  $V_{1s}=V_{1r}=V_{2s}=V_{2r}=1$  p.u., and with fixed angles resulting in transmission angles,  $\delta_1=\delta_2$ .

The line impedances and the rating of the two compensating voltage sources are identical, that is  $V_{1pqmax}=V_{2pqmax}$  and  $X_1=X_2=0.5$  p.u.

Figure 3 is the phasor diagram defining the relationship between  $V_{1s}$ ,  $V_{x1}$  and the inserted phasor voltage  $V_{1pq}$ . The inserted voltage phasor  $V_{1pq}$  is added to the fixed end voltage phasor  $V_{1s}$  to produce the effective sending end voltage. The difference between  $V_{1s}$  and  $V_{1}$ , gives the compensated voltage  $V_{x1}$  across  $X_1$ . As  $r_1$  is varied over its full 360 range, the end of phasor  $V_{1pq}$  moves along a circle with its centre at the end of  $V_{1s}$ . The rotation of phasor  $V_{1pq}$  with angle  $r_1$  modulates both the magnitude and angle phasor  $V_{x1}$  and therefore both real power  $P_{1R}$  and reactive power  $Q_{1R}$  vary with  $r_1$  in a sinusoidal manner as shown in Fig. 4. The Voltage Source inverter ( $V_{1pq}$ ) supplies or absorbs both real power ( $P_{1pq}$ ) and reactive power ( $Q_{1pq}$ ), which are also sinusoidal functions of angle  $r_1$ .

## RESULTS

The circuit model of IPFC is shown in Fig. 5a. The series transformers are represented as voltage dependent voltage sources. The real power waveform without IPFC is shown in Fig. 5b. The real power with IPFC is shown in Fig. 5c. From Fig. 5c, it can be seen that the real power is increased.

The circuit model of IPFC with different values of voltages is shown in Fig. 6a. Lines 1study 2 operate at 11kv and 10kv, respectively. From Fig. 6c, it can be observed that the reactive power is increased.




Fig. 5a: Circuit model of IPFC with phase different




Fig. 5b: Real power with out IPFC




Fig. 5c: Real power with out IPFC

The circuit model with different phase angles is shown in Fig. 7a. Sources at lines1 and 2 operate at  $20^\circ$  and  $30^\circ$  respectively. Real and reactive powers in line1 are shown in Fig. 7b study c respectively. Real and reactive powers in line 2 are shown in Fig. 7d study e, respectively.




Fig. 6a: Circuit model of IPFC with different values and voltages




Fig. 6b: The Reactive power with out IPFC




Fig. 6c: The reactive power with IPFC

**Closed loop system:** IPFC closed loop with phase angle difference between two lines is shown in Fig. 8. Two transmission lines, one with phase angle  $0^\circ$  and other with the  $20^\circ$  considered. To show the difference in power flow between two lines for difference phase angle between supply, two voltage




Fig. 7a: Circuit model with different phase angles




Fig. 7b: Real power in line1




Fig. 7c: Reactive power in line1




Fig. 7d: Real power in line2




Fig. 7e: Reactive power in line 2




Fig. 8: Circuit model of closed loop system with phase difference




Fig. 8a: Input power in the over loaded line with compensation

sources are considered at the second transmission line. one source operates phase angle  $0^\circ$  and other with  $20^\circ$ .




Fig. 8b: Input power of over loaded line without compensation




Fig. 8c: Input power in the normal loaded line with compensation

Real power with and without compensation over loaded line is shown in the Fig. 8a and b. From Fig. 8a and b it can be seen that real power drawn from the source with compensation is less than the real power drawn from the source without compensation. Figure 8c shows that input power in the normal load line with compensation.

### CONCLUSION

Circuit model with phase difference and voltage difference were simulated to study the real and reactive power flows. The circuit model for open loop and closed

loop systems are presented. They are used to simulate the two line system to study real and reactive power flows. It is observed that the real and reactive powers are increased by the presence of IPFC. The IPFC is a viable solution to balance the power flow in a transmission system.

### REFERENCES

Gyugyi, L., K.K. Sen and C.D. Schauder, 1998. The Interline Power Flow Controller Concept. A New Approach to Power Flow Management in Transmission Systems, IEEE/PES. Summer Meeting, Paper No. PE-316-PWRD-0-07-1998, San Diego.

Gyugyi, L., K.K. Sen and C.D. Schauder, 1999. The Interline Power Flow Controller Concept. A New Approach to Power Flow Management in Transmission Systems, IEEE. Trans. Power. Delivery, pp: 1115-1123.

Gyugyi, L., 2000. Application Characteristics of Converter-Based FACTS Controllers. Int. Conf. Power Con., pp: 391-396.

Hingorani, N.G. and L. Gyugyi, 2000. Understanding FACTS. Concepts and technology of flexible A.C. transmission system, IEEE. Press.

Jianghong Chen, Tjing T. Lie, D.M. Vilathgamua, 2000. Basic Control of Interline Power Flow Controller, IEEE. Transaction on Power System.

Papic, I., P. Zunko, D. Povh and M. Weinhold, 1997. Basic Control of Unified Power Flow Controller, IEEE. Trans. Power Sys., pp: 1734-1739.

Sen, K.K., 1998. SSSC-Static Synchronous Series Compensator. Theory Modelling and Applications IEEE. Trans. Power Delivery, pp: 241-246.

Song, Y.H. and A.T. Johns, 1999. Flexible A.C. Transmission System. IEEE. Book Series on Power Engineering.

Zhang, X.P., 2003. Modeling of the Inter line Power Flow controller and the generalized Unified Power Flow Controller (UPFC) in Newton power flow. IEEE. Proceedings on Generation Transmission-Distribution, pp: 268-274.